

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7170-0595:114 Page 1 of 1

**CATEGORY:** Control Units (High-Rise)

**LISTEE:** Ansul Incorporated, One Stanton Street, Marinette, WI 54143-2542  
Contact: Lyle McDonald (715) 735-7411 Fax (715) 732-3634

**DESIGN:** Models Autopulse Z-28 (430532) and Z-28 (430539) fire alarm control units. Power limited, automatic, manual, local, auxiliary, remote station (protected premises), proprietary (protected premise), waterflow and sprinkler supervisory service. Suitable for releasing device service. Refer to listee's data sheet for detailed product description and operational considerations. For use with the following separately listed TEPG-US (CSFM Listing No. 7170-1597:116) System components:

430607	City Circuit Card
430606	Class A Adapter
430610	RS-232 Service Modem
430611	Expansion Power Supply
430612	Suppression Release Kit
430617	Battery Meter Module
430619	Expansion Supply
430620	Suppression Release Kit
430687	Coil Supervision Module

**RATING:** 120, 220, 240 VAC primary; 24 VDC secondary

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as fire alarm control unit for use with separately listed compatible initiating and indicating devices. Suitable for high-rise application when installed with Simplex Model 4003 Series (CSFM Listing No. 6911-0026:196) voice communication system. Refer to listee's Installation Instructions Manual for details.

These control units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition.

**NOTE:** For **Fire Alarm Verification Feature (delay of fire alarm signal)**, the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

**XLF:** 7170-0026:226

04-14-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 15, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**